

PONDEROSA BASIN MUTUAL WATER COMPANY

MONTHLY WATER OPERATOR'S REPORT

April 2018

- All monthly samples for the State Water-Board are good.
- The cross-connection survey data has been completed and turned over for review by the state.
- Well #3 was disconnected due to it not being in use.
- PG &E power bill is one of the lowest ever-due to manually switching wells and pumps on and off with demand and tank levels.
- Our average water pumped per day is 50,000 gpd.
- A meter was installed at Well #8 per state guidelines. Meter will also be installed at Wells 9 & 10.
- The income survey that is being done by CRWA is still not being responded to. CRWA has tried several mailings and we put an notification in the Mariposa Gazette; but they still have not gotten the number of responses needed for us to apply for grant funding.
- **JUST A REMINDER:** the new watering schedule stated on **April 1, 2018.**

Reported by
Tuffy Donati
Water Operations Manager